



Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasaheb varad path, Solapur-413003
Tel. no. 0217-2740350
Email - smcphewtr@gmail.com

PHE/BHIMA- 1378
Dt. 1/2/2024

Water testing report of Soregaon WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Slightly greenish	Clear		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	3.9	0.7	1.0	5.0
4	pH Values	8.19	7.60	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	302.95	299.95	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO ₃)	400	390	200	600
8	Alkalinity (as CaCO ₃)	290	280	200	600
9	Total Dissolved Solids	954	962	500	2000
10	Residual chlorine	-	4.5	--	--
10	Dissolved oxygen	1.2	6.5	6.5	8.0
11	Electrical conductivity	-	-		
12	Bacterial count (MPN)	4 + + + +ve	no any change		

R.S.A.

Chemist
Soregaon WTP