



Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasaheb varad path, Solapur-413003
Email - smepheotr@gmail.com Tel.no.0217-2740350

PHE/BHIMA-1322

दि 11/12/2023

Water testing report of Soregaon WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Slightly greenish	Clear		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	3.8	0.6	1.0	5.0
4	pH Values	8.09	7.69	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	214.95	209.95	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO3)	340	330	200	600
8	Alkalinity (as CaCO3)	260	250	200	600
9	Total Dissolved Solids	760	765	500	2000
10	Residual chlorine	-	4.5	--	--
10	Dissolved oxygen	1.2	6.4	6.5	8.0
11	Electrical conductivity	-	-		
12	Temperature	-	-		
13	Bacterial count (MPN)	-	-		

R.S.K
Chemist
Soregaon WTP