



# Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasaheb varad path, Solapur-413003


Email - [smcphewtr@gmail.com](mailto:smcphewtr@gmail.com)

Tel.no: 0217-2740350

Dt. 07/08/2023

## Water testing report of Pakani WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	clear	clear		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	1.7	0.4	1.0	5.0
4	pH Values	7.6	7.3	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	60	40	250	1000
6	Ammonia	0.0	0.0	0.5	No relaxation
7	Total Hardness (as CaCO <sub>3</sub> )	170	150	200	600
8	Alkalinity (as CaCO <sub>3</sub> )	140	130	200	600
9	Total Dissolved Solids	298	304	500	2000
10	Residual chlorine	-	4ppm		

  
Chemist  
Pakani WTP