



Solapur Municipal Corporation, Solapur  
Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasaheb varad path, Solapur-413003


Email - [smcphewr@gmail.com](mailto:smcphewr@gmail.com)

Tel.no.0217-2740350

Dt 24/04/2023

Water testing report of Pakani WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	clear	clear		
2	Odour	Odourness	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	2.9	0.4	1.0	5.0
4	pH Values	7.8	7.5	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	90	70	250	1000
6	Ammonia	0.0	0.0	0.5	No relaxation
7	Total Hardness (as CaCO <sub>3</sub> )	200	170	200	600
8	Alkalinity (as CaCO <sub>3</sub> )	150	140	200	600
9	Total Dissolved Solids	304	312	500	2000
10	Residual chlorine	-	4ppm	--	--

  
Chemist  
Pakani WTP