



Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasaheb varad path, Solapur-413003
Tel.no.0217-2740350
Email - smepheptr@gmail.com

PHE/BHIMA- 1377
दि.31 / 1 / 2023

Water testing report of Soregaon WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Slightly greenish	Clear		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	4.1	0.6	1.0	5.0
4	pH Values	8.09	7.64	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	299.90	294.90	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO ₃)	400	390	200	600
8	Alkalinity (as CaCO ₃)	290	280	200	600
9	Total Dissolved Solids	976	984	500	2000
10	Residual chlorine	—	4.5	--	--
10	Dissolved oxygen	1.2	6.4	6.5	8.0
11	Electrical conductivity	—	—		
12	Bacterial count (MPN)	Samples taken in incubator?		kept for	

R.S.K.
Chemist
Soregaon WTP