



Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasaheb varad path, Solapur-413003
Email - smcphewtr@gmail.com Tel.no.0217-2740350

दि. 17/ 4/2024

PHE/BHIMA- 1473

Water testing report of Soregaon WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Slightly greenish	Clear		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	2.8	0.8	1.0	5.0
4	pH Values	8.16	7.84	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	129.96	124.96	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO ₃)	210	200	200	600
8	Alkalinity (as CaCO ₃)	190	185	200	600
9	Total Dissolved Solids	446	452	500	2000
10	Residual chlorine	—	4.5	--	--
11	Dissolved oxygen	1.9	6.7	6.5	8.0
12	Bacterial count (MPN)	Samples taken & kept for incubation.			

R.S.A
Chemist
Soregaon WTP