



Dt-15-02-2023

## Solapur Municipal Corporation, Solapur

### Public Health Engineer Department

Indrabhuvan Railway Line, Punyashlok Appasaheb varad Peth, Solapur-413003

Email:- [smcphewtr@gmail.com](mailto:smcphewtr@gmail.com)

Tel.No.0217-2740350

## Water Testing Report Bhavani Peth WTP

Sr.No.	Test Parameter	Raw Water	Treated Water	BIS Specification 10500:2012 Normal Values	
				Desirable Limits	Permissible Limits
1	Physical appearance	colourless	colourless		
2	Odour	odourless	odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	3.5	0.4	1.0	5.0
4	pH Values	7.25	6.95	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	74.97	72.48	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total hardness (as CaCO <sub>3</sub> )	230	220	200	600
8	Alkalinity (as CaCO <sub>3</sub> )	100	95	200	600
9	Total Dissolved solids	277	280	500	2000
10	Residual chlorine	—			
11	Dissolved Oxygen	—		6.5	8.0
12	Electrical conductivity	—			
13	Temperature	—			
14	Bacterial count (MPN)	16	0		

S.D.Jadhav

Chemist  
Bhavani Peth WTP