



# Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasaheb varad path, Solapur-413003  
Email - [smepheutr@gmail.com](mailto:smepheutr@gmail.com)  
Tel.no.0217-2740350

PHE/BHIMA-1316

दि. 7/12/2023

## Water testing report of Soregaon WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Slightly greenish	Clear		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	3-8	0.6	1.0	5.0
4	pH Values	8.09	7.64	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	196.95	194.95	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO <sub>3</sub> )	340	330	200	600
8	Alkalinity (as CaCO <sub>3</sub> )	240	235	200	600
9	Total Dissolved Solids	725	730	500	2000
10	Residual chlorine	—	4.5	--	--
10	Dissolved oxygen	1.2	6.7	6.5	8.0
11	Electrical conductivity	—	—		
12	Temperature.	—	—		
13	Bacterial count (MPN)	3 + + +ve	no any change		

*RS*  
Chemist

Soregaon WTP