



Dt-04-12-2023

Solapur Municipal Corporation, Solapur
Public Health Engineer Department

Indrabhuvan Railway Line, Punyashlok Appasaheb varad Peth, Solapur-413003

Email :- smcphewtr@gmail.com

Tel.No.0217-2740350

Water Testing Report Bhavani Peth WTP

Sr.No.	Test Parameter	Raw Water	Treated Water	BIS Specification 10500:2012 Normal Values	
				Destrable Limits	Permissible Limits
1	Physical appearance	Clean	clean		
2	Odour	odourness	odourness	Agreeable	Agreeable
3	Turbidity (as NTU)	2.4	0.5	1.0	5.0
4	pH Values	7.20	6.97	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	74.97	72.48	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total hardness (as CaCO ₃)	220	210	200	600
8	Alkalinity (as CaCO ₃)	100	95	200	600
9	Total Dissolved solids	293	297	500	2000
10	Residual chlorine	—	4.0		
11	Dissolved Oxygen	—		6.5	8.0
12	Electrical conductivity	—			
13	Temperature	—			
14	Bacterial count (MPN)	16	0		

S.D.Jadhav

Chemist

Bhavani Peth WTP