



Dt - 26-12-23

Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan Railway Line, Punyashlok Appasaheb varad Peth, Solapur-413003

Email :- smcphewtr@gmail.com

Tel.No.0217-2740850

Water Testing Report Bhavani Peth WTP

Sr.No.	Test Parameter	Raw Water	Treated Water	DIS Specification 10500:2012	
				Normal Values	
				Desirable Limits	Permissible Limits
1	Physical appearance	clean	clean		
2	Odour	odourless	odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	2.8	0.4	1.0	5.0
4	pH Values	6.97	6.85	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	72.48	69.97	250	1000
6	Aminonia	Absent	Absent	0.5	No relaxation
7	Total hardness (as CaCO ₃)	210	200	200	600
8	Alkalinity (as CaCO ₃)	100	95	200	600
9	Total Dissolved solids	292	300	500	2000
10	Residual chlorine	-	4.0		2.0
11	Dissolved Oxygen	-			5.5
12	Electrical conductivity	-		6.5	500
13	Temperature	-			
14	Bacterial count (MPN)	16	0		

S.D. Jadhav

Chemist
Bhavani Peth WTP