



Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasaheb varad path, Solapur-413003
Email - smepheutr@gmail.com Tel.no.0217-2740350

PHE/BHIMA- 1465

दि. 9/4/2024

Water testing report of Soregaon WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Slightly greenish	Clean		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	3.2	0.7	1.0	5.0
4	pH Values	8.19	7.84	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	129.96	124.96	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO ₃)	200	190	200	600
8	Alkalinity (as CaCO ₃)	180	170	200	600
9	Total Dissolved Solids	425	431	500	2000
10	Residual chlorine	—	4.5	--	--
11	Dissolved oxygen	1.6	6.7	6.5	8.0
12	Bacterial count (MPN)	—	—		


Chemist
Soregaon WTP