



Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhayan, Railway line, punyashlok appasaheb yarad path, Solapur-413003


Email - smidphewtr@gmail.com

Tel.no: 0217-2740350

Dt 05/06/2023

Water testing report of Pakani WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	clear	clear		
2	Odour	odourless	odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	1.9	0.3	1.0	5.0
4	pH Values	7.7	7.4	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	60	50	250	1000
6	Ammonia	0.0	0.0	0.5	No relaxation
7	Total Hardness (as CaCO ₃)	180	160	200	600
8	Alkalinity (as CaCO ₃)	130	120	200	600
9	Total Dissolved Solids	287	294	500	2000
10	Residual chlorine	-	4.8 ppm		


Chemist
Pakani WTP