

PHE/BHIMA-



Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasaheb varad path, Solapur-413003

Email - smcphewtr@gmail.com

Tel.no.0217-2740350

PHE/BHIMA-1354

दि. 10 / 1 / 2023

Water testing report of Soregaon WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Slightly greenish	Clean		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	3.8	0.6	1.0	5.0
4	pH Values	8.01	7.64	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	296.95	294.95	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO ₃)	380	370	200	600
8	Alkalinity (as CaCO ₃)	280	265	200	600
9	Total Dissolved Solids	856	861	500	2000
10	Residual chlorine	—	4.5	—	—
10	Dissolved oxygen	1.6	6.4	6.5	8.0
11	Electrical conductivity	—	—		
12	Temperature	—	—		
13	Bacterial count (MPN)	Samples taken & kept for incubation			

Chemist
Soregaon WTP