



Solapur Municipal Corporation, Solapur

Public Health Engineer Department -

Indrabhayan, Railway line, punyashlok appasaheb varad path, Solapur-413003


Email - smphewtr@gmail.com

Tel. no. 0217-2740350

Dt 30/10/2023

Water testing report of Pakani WTP

| Sr.No | Test Parameter | Raw Water | Treated Water | BIS Specification 10500 : 2012 Normal values | |
|-------|--|---------------------|---------------|--|--------------------|
| | | | | Desirable Limits | Permissible Limits |
| 1 | Physical appearance | Suspended Particles | Clear | | |
| 2 | Odour | Odourless | Odourless | Agreeable | Agreeable |
| 3 | Turbidity (as NTU) | 1.6 | 0.4 | 1.0 | 5.0 |
| 4 | pH Values | 7.6 | 7.3 | 6.5 to 8.5 | No relaxation |
| 5 | Chlorides (as Cl) | 60 | 50 | 250 | 1000 |
| 6 | Ammonia | 0.0 | 0.0 | 0.5 | No relaxation |
| 7 | Total Hardness (as CaCO ₃) | 160 | 140 | 200 | 600 |
| 8 | Alkalinity (as CaCO ₃) | 120 | 100 | 200 | 600 |
| 9 | Total Dissolved Solids | 262 | 266 | 500 | 2000 |
| 10 | Residual chlorine | - | 4ppm | | |


Chemist
Pakani WTP