



Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuyan, Railway line, punyashlok appasaheb varad path, Solapur-413003


Email - smphewtr@gmail.com

Tel.no. 0217-2740350

Dt. 12/01/2023

Water testing report of Pakani WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Clear	Clear		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	2.4	0.5	1.0	5.0
4	pH Values	7.9	7.6	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	30	70	250	1000
6	Ammonia	0.0	0.0	0.5	No relaxation
7	Total Hardness (as CaCO ₃)	200	180	200	600
8	Alkalinity (as CaCO ₃)	130	110	200	600
9	Total Dissolved Solids	301	302	500	2000
10	Residual chlorine	-	4.8 ppm		


Chemist
Pakani WTP