



# Solapur Municipal Corporation, Solapur

Public Health Engineer Department -

Indrabhuyan, Railway line, punyashlok appasaheb, varad path, Solapur-413003


Email - [smidphewtr@gmail.com](mailto:smidphewtr@gmail.com)

Tel.no-0217-2740350

Dt. 07/03/2024

## Water testing report of Pakani WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Slightly muddy	clear		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	2.9	0.4	10	5.0
4	pH Values	8.23	7.82	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	60	50	250	1000
6	Ammonia	0.0	0.0	0.5	No relaxation
7	Total Hardness (as CaCO <sub>3</sub> )	230	200	200	600
8	Alkalinity (as CaCO <sub>3</sub> )	190	170	200	600
9	Total Dissolved Solids	264	270	500	2000
10	Residual chlorine	-	4ppm		

  
Chemist  
Pakani WTP