



Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasaheb varad path, Solapur - 413003


Email - smcphewtr@gmail.com

Tel. no. 0217-2740350

Dt 12/10/2023

Water testing report of Pakani WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Suspended particles	clear		
2	Odour	odourless	odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	1.7	0.2	1.0	5.0
4	pH Values	7.5	7.2	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	60	40	250	1000
6	Ammonia	0.0	0.0	0.5	No relaxation
7	Total Hardness (as CaCO ₃)	190	160	200	600
8	Alkalinity (as CaCO ₃)	120	100	200	600
9	Total Dissolved Solids	286	284	500	2000
10	Residual chlorine	-	4 ppm		


Chemist
Pakani WTP