

मा. सावे राजे



## Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasaheb varad path, Solapur-413003  
Email - [smepheutr@gmail.com](mailto:smepheutr@gmail.com) Tel.no.0217-2740350

PHE/BHIMA-953

दि. 27/1/2023

### Water testing report of Soregaon WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Slightly greenish	Clean		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	4.9	0.6	1.0	5.0
4	pH Values	8.21	7.69	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	299.95	294.95	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO <sub>3</sub> )	380	370	200	600
8	Alkalinity (as CaCO <sub>3</sub> )	260	255	200	600
9	Total Dissolved Solids	822	829	500	2000
10	Residual chlorine	—	4.5	--	--
10	Dissolved oxygen	2.1	6.1	6.5	8.0
11	Electrical conductivity	0-84	0-82		
12	Temperature	—	—		
13	Bacterial count (MPN)	16	0		

*R.S.*  
Chemist  
Soregaon WTP