



Dt - 28-07-2023

# Solapur Municipal Corporation, Solapur

## Public Health Engineer Department

Indrabhuvan Railway Line, Punyashlok Appaszheb varad Peth, Solapur-413003

Email :- [smcphevr@gmail.com](mailto:smcphevr@gmail.com)

Tel.No.0217-2740350

### Water Testing Report Bhavani Peth WTP

Sr.No.	Test Parameter	Raw Water	Treated Water	BIS Specification 10500:2012 Normal Values	
				Desirable Limits	Permissible Limits
1	Physical appearance	clean	clean		
2	Odour	odourless	odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	3.7	0.4	1.0	5.0
4	pH Values	7.14	7.02	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	79.97	77.48	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total hardness (as CaCO <sub>3</sub> )	230	220	200	600
8	Alkalinity (as CaCO <sub>3</sub> )	110	105	200	600
9	Total Dissolved solids	283	288	500	2000
10	Residual chlorine	—	4.0		
11	Dissolved Oxygen	—			
12	Electrical conductivity	—		6.5	8.0
13	Temperature	—			
14	Bacterial count (MPN)	16	0		

S.D. Jadhav  
Chemist  
Bhavani Peth WTP