



Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan.Railway line.punyashlok appasaheb varad path.Solapur-413003
Email - smepheotr@gmail.com Tel.no.0217-2740350

PHE/BHIMA-1311

दि. 6/12/2023

Water testing report of Soregaon WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Slightly greenish	Clean		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	4.2	0.6	1.0	5.0
4	pH Values	8.06	7.61	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	194.95	189.95	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO ₃)	300	290	200	600
8	Alkalinity (as CaCO ₃)	210	200	200	600
9	Total Dissolved Solids	719	724	500	2000
10	Residual chlorine	-	4.5	--	--
10	Dissolved oxygen	1.2	6.4	6.5	8.0
11	Electrical conductivity	-	-		
12	Temperature	-	-		
13	Bacterial count (MPN)	Samples taken & kept for incubat.			

RSK
Chemist
Soregaon WTP