



**Solapur Municipal Corporation, Solapur**

Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasaheb varad path, Solapur-413003

Email – [smcpheutr@gmail.com](mailto:smcpheutr@gmail.com)

Tel.no.0217-2740350

PHE/BHIMA- 1485

दि.26/4/2024

**Water testing report of Soregaon WTP**

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Slightly greenish	Clean		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	3.1	0.7	1.0	5.0
4	pH Values	7.96	7.74	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	131.96	129.96	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO <sub>3</sub> )	210	200	200	600
8	Alkalinity (as CaCO <sub>3</sub> )	180	170	200	600
9	Total Dissolved Solids	420	425	500	2000
10	Residual chlorine	—	4.5	--	--
11	Dissolved oxygen	1.6	6.6	6.5	8.0
12	Bacterial count (MPN)	16	0		

*R.S.A.*

**Chemist  
Soregaon WTP**