



Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuyan, Railway line, punyashlok appasaheb yarad path, Solapur-413003


Email - snidphewtr@gmail.com

Tel. no-0217-2740350

Dt 06/03/2024

Water testing report of Pakani WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	suspended particles	clear		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	2.5	0.6	1.0	5.0
4	pH Values	8.12	7.62	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	80	50	250	1000
6	Ammonia	0.0	0.0	0.5	No relaxation
7	Total Hardness (as CaCO ₃)	210	190	200	600
8	Alkalinity (as CaCO ₃)	170	150	200	600
9	Total Dissolved Solids	256	262	500	2000
10	Residual chlorine	-	4ppm		


Chemist
Pakani WTP