



Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasaheb varad path, Solapur-413003

Email – smepheptr@gmail.com

Tel.no.0217-2740350

PHE/BHIMA-43

दि.21/3/2025

Water testing report of Soregaon WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
		Slightly greenish	01 Clean		
1	Physical appearance				
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	4.9	0.6	1.0	5.0
4	pH Values	8.16	7.62	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	329.95	324.95	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO ₃)	390	380	200	600
8	Alkalinity (as CaCO ₃)	340	330	200	600
9	Total Dissolved Solids	746	752	500	2000
10	Residual chlorine	—	4.5	--	--
10	Dissolved oxygen	2.7	6.9	6.5	8.0
11	Electrical conductivity	—	—		
12	Temperature	—	—		
13	Bacterial count (MPN)	16	0		

R.S. /
Chemist
Soregaon WTP