



Dt - 15-02-2025

# Solapur Municipal Corporation, Solapur

## Public Health Engineer Department

Indrabhuvan Railway Line, Panyashlek Appasheb varad Peth, Solapur-413003

Email :- [smcphewtr@gmail.com](mailto:smcphewtr@gmail.com)

Tel.No.0217-2740350

### Water Testing Report Bhavani Peth WTP

Sr.No.	Test Parameter	Rnw Water	Treated Water	DIS Specification 10500:2012 Normal Values	
				Desirable Limits	Permissible Limits
1	Physical appearance	slightly green	colourless		
2	Odour	odourness	odourness	Agreeable	Agreeable
3	Turbidity (as NTU)	3.4	0.8	1.0	5.0
4	pH Values	7.03	7.08	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	104.47	98.97	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total hardness (as CaCO <sub>3</sub> )	250	240	200	600
8	Alkalinity (as CaCO <sub>3</sub> )	100	95	200	600
9	Total Dissolved solids	282	286	500	2000
10	Residual chlorine	-	4.0		
11	Dissolved Oxygen	-			
12	Electrical conductivity	-		6.5	8.0
13	Temperature	-			
14	Bacterial count (MPN)	16	0		

S. D. Jadhav  
Chemist  
Bhavani Peth WTP

