



Dt-13-03-2025

**Solapur Municipal Corporation, Solapur**  
**Public Health Engineer Department**

Indrabhuvan Railway Line, Punyashlok Appasheb varad Peth, Solapur-413003

Email :- [smcphewtr@gmail.com](mailto:smcphewtr@gmail.com)

Tel.No.0217-2740350

**Water Testing Report Bhavani Peth WTP**

Sr.No.	Test Parameter	Raw Water	Treated Water	BIS Specification 10500:2012 Normal Values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Slightly green	Colourless		
2	Odour	Odourless	odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	2.1	0.6	1.0	5.0
4	pH Values	7.03	7.05	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	102.48	97.48	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total hardness (as CaCO <sub>3</sub> )	270	260	200	600
8	Alkalinity (as CaCO <sub>3</sub> )	100	95	200	600
9	Total Dissolved solids	281	289	500	2000
10	Residual chlorine	-	4.0		
11	Dissolved Oxygen	-			
12	Electrical conductivity	-		6.5	8.0
13	Temperature	-			
14	Bacterial count (MPN)	16	0		

S.D. Jadhav  
Chemist  
Bhavani Peth WTP