



सोलापूर महानगरपालिका, सोलापूर
ईंद्रभुवन, रेल्वे लाईन्स, पुण्यश्लोक आप्पासाहेब वारद पथ,
सोलापूर- ४१३००९
सार्वजनिक आरोग्य अभियंता यांचे कार्यालय
ई मेल : smcpheutr@gmail.com टेलिफोन नं:-०२९७-
२७४०३५०



जाक्र.साआअ/भीमा 1624

Date : 29/8/24

Water testing report of Soregaon WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	turbid	Clean		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	190	0.4	1.0	5.0
4	pH Values	7.49	6.72	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	84.95	81.95	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO3)	160	150	200	600
8	Alkalinity (as CaCO3)	160	150	200	600
9	Total Dissolved Solids	305	309	500	2000
10	Residual chlorine	-	4.5	--	--
11	Dissolved oxygen	1.9	7.2	6.5	8.0
12	Bacterial count (MPN)	47.7. +ve	no any change		

RS
Chemist
Soregaon WTP