



## Solapur Municipal Corporation, Solapur

### Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasaheb varad path, Solapur-413003  
Email – [smcphewtr@gmail.com](mailto:smcphewtr@gmail.com)

Tel.no.0217-2740350

PHE/BHIMA-1698

दि. 2 / 2 / 2025

### Water testing report of Soregaon WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Slightly greenish	Clear		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	4.1	0.5	1.0	5.0
4	pH Values	8.01	7.64	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	324.95	319.95	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO <sub>3</sub> )	360	350	200	600
8	Alkalinity (as CaCO <sub>3</sub> )	300	290	200	600
9	Total Dissolved Solids	612	611	500	2000
10	Residual chlorine	-	4.5	--	--
10	Dissolved oxygen	1.9	6.7	6.5	8.0
11	Bacterial count (MPN)	-	-		

*R.S.*  
Chemist  
Soregaon WTP