



Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasaheb varad path, Solapur-413003

Email – smcpheutr@gmail.com

Tel.no.0217-2740350

PHE/BHIMA-1668

दि. 8 / 10 / 2024

Water testing report of Soregaon WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
			01		
1	Physical appearance	Clean	Clean		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	4.1	0.6	1.0	5.0
4	pH Values	7.72	7.31	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	109.95	104.95	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO ₃)	180	175	200	600
8	Alkalinity (as CaCO ₃)	180	170	200	600
9	Total Dissolved Solids	320	326	500	2000
10	Residual chlorine	—	4.5	--	--
11	Dissolved oxygen	2.1	6.7	6.5	8.0
12	Bacterial count (MPN)	—	—		

R.S. /

Chemist
Soregaon WTP