



Dt - 12-06-24

Solapur Municipal Corporation, Solapur
Public Health Engineer Department

Indrabhuvan Railway Line, Punvashek Appasaheb varad Peth, Solapur-413003

Email :- smcphewtr@email.com

Tel.No.0217-2740350

Water Testing Report Bhavani Peth WTP

Sr.No.	Test Parameter	Raw Water	Treated Water	BIS Specification 10500:2012 Normal Values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Clean	Clean		
2	Odour	odourless	odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	1.9	0.5	1.0	5.0
4	pH Values	7.04	7.08	6.5 to 8.5	No relaxation
5	Chlorides (as Cl ⁻)	92.48	87.97	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total hardness (as CaCO ₃)	230	220	200	600
8	Alkalinity (as CaCO ₃)	80	75	200	600
9	Total Dissolved solids	315	325	500	2000
10	Residual chlorine	-	4.0		
11	Dissolved Oxygen	-		6.5	8.0
12	Electrical conductivity	-			
13	Temperature	-			
14	Bacterial count (MPN)	16	0		

S. P. Gadhave

Chemist

Bhavani Peth WTP