



Dt-14-09-2024

Solapur Municipal Corporation, Solapur  
Public Health Engineer Department

Indrabhuvan Railway Line, Punyashlok Appasaheb varad Peth, Solapur-413003

Email :- [smcphewtr@email.com](mailto:smcphewtr@email.com)

Tel.No.0217-2740350

Water Testing Report Bhaveni Peth WTP

Sr.No.	Test Parameter	Raw Water	Treated Water	BIS Specification 10500:2012 Normal Values	
				Desirable Limits	Permissible Limits
1	Physical appearance	clean	clean		
2	Odour	odourless	odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	1.2	0.5	1.0	5.0
4	pH Values	7.15	7.18	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	98.48	94.42	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total hardness (as CaCO <sub>3</sub> )	220	210	200	600
8	Alkalinity (as CaCO <sub>3</sub> )	80	75	200	600
9	Total Dissolved solids	271	279	500	2000
10	Residual chlorine	—	4.0		
11	Dissolved Oxygen	—		6.5	8.0
12	Electrical conductivity	—			
13	Temperature	—			
14	Bacterial count (MPN)	16	0		

S.D. Jadhav  
Chemist  
Bhaveni Peth WTP

