



Dt - 24-08-2024

# Solapur Municipal Corporation, Solapur

## Public Health Engineer Department

Indrabhuvan Railway Line, Punyashlok Appasaheb varad Peth, Solapur-413003

Email :- [smephewr@gmail.com](mailto:smephewr@gmail.com)

Tel.No.0217-2740350

### Water Testing Report Bhayani Peth WTP

Sr.No.	Test Parameter	Raw Water	Treated Water	DIS Specification 10500:2012 Normal Values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Clean	Clean		
2	Odour	odourless	odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	2.6	0.9	1.0	5.0
4	pH Values	6.98	6.96	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	112.48	104.97	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total hardness (as CaCO <sub>3</sub> )	260	250	200	600
8	Alkalinity (as CaCO <sub>3</sub> )	100	90	200	500
9	Total Dissolved solids	272	279	500	2000
10	Residual chlorine	—	4.0		
11	Dissolved Oxygen	—		5.5	8.0
12	Electrical conductivity	—			
13	Temperature	—			
14	Bacterial count (MPN)	16	0		

S.D. Jadhav  
Chemist

Bhayani Peth WTP

