



Dt- 26-08-2024

Solapur Municipal Corporation, Solapur  
Public Health Engineer Department

Indrabhuvan Railway Line, Punyashlok Appasaheb varad Peth, Solapur-413003

Tel.No.0217-2740350

Email :- [smcphewtr@gmail.com](mailto:smcphewtr@gmail.com)

Water Testing Report Bhavani Peth WTP

| Sr.No. | Test Parameter                         | Raw Water  | Treated Water | BIS Specification 10500:2012 Normal Values |                    |
|--------|--|------------|---------------|--|--------------------|
|        |  |            |               | Desirable Limits                           | Permissible Limits |
| 1      | Physical appearance                    | Colourless | Colourless    |  |                    |
| 2      | Odour                                  | Odourless  | Odourless     | Agreeable                                  | Agreeable          |
| 3      | Turbidity (as NTU)                     | 1.2        | 0.8           | 1.0  | 5.0                |
| 4      | pH Values                              | 7.92       | 7.08          | 6.5 to 8.5                                 | No relaxation      |
| 5      | Chlorides (as Cl)                      | 114.48     | 109.97        | 250  | 1000               |
| 6      | Aminonia                               | Absent     | Absent        | 0.5  | No relaxation      |
| 7      | Total hardness (as CaCO <sub>3</sub> ) | 240        | 230           | 200  | 600                |
| 8      | Alkalinity (as CaCO <sub>3</sub> )     | 90         | 85            | 200  | 600                |
| 9      | Total Dissolved solids                 | 275        | 281           | 500  | 2000               |
| 10     | Residual chlorine                      | -          | 4.0           |  |                    |
| 11     | Dissolved Oxygen                       | -          |               | 6.5  | 8.0                |
| 12     | Electrical conductivity                | -          |               |  |                    |
| 13     | Temperature                            | -          |               |  |                    |
| 14     | Bacterial count (MPN)                  | 16         | 0             |  |                    |

S.D. Jadhav

Chemist  
Bhavani Peth WTP

Scanned with OKEN Scanner



Scanned with OKEN Scanner